
| Energy performance certificate (EPC) | | | | |
|--|------------------|--------------------------|--------------------------|--|
| 62 Stopoloigh Proodway | Energy rating | Valid until: | 22 May 2034 | |
| 62 Stoneleigh Broadway STONELEIGH KT17 2HS | C | Certificate number: | 8487-5231-4224-9150-5335 | |
| Property type | | Retail/Financial and Pro | ofessional Services | |
| Total floor area | 79 square metres | | | |

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock



| Main heating fuel | Grid Supplied Electricity |
|--|---------------------------|
| Building environment | Air Conditioning |
| Assessment level | 3 |
| Building emission rate (kgCO2/m2 per year) | 15.66 |
| Primary energy use (kWh/m2 per year) | 167 |

13 A

53 C

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report (/energy-certificate/4910-4542-3166-2969-3580)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

| Assessor's name | James Money |
|-----------------|---------------------------------|
| Telephone | 07714 291998 |
| Email | james@surreyenergyratings.co.uk |

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

| Accreditation scheme | Elmhurst Energy Systems Ltd |
|----------------------|--------------------------------|
| Assessor's ID | EES/019669 |
| Telephone | 01455 883 250 |
| Email | enquiries@elmhurstenergy.co.uk |

About this assessment

| Employer | Surrey Energy Ratings Ltd |
|------------------------|---|
| Employer address | 33 Albany Park Road, Leatherhead, KT22 7PA |
| Assessor's declaration | The assessor is not related to the owner of the property. |
| Date of assessment | 23 May 2024 |
| Date of certificate | 23 May 2024 |